



# Mohawk Valley Water Authority Hinckley 36" Raw Water Main Repair



15 million gallons per day leak called in on July 4<sup>th</sup>. Located and confirmed on 36" main at midnight.



Inspecting leaking section of 36" pipe 10' long crack along bottom.



Laying out temporary valve locations and temporary bypass piping.



MOHAWK VALLEY  
WATER AUTHORITY

# Mohawk Valley Water Authority Hinckley 36" Raw Water Main Repair



Preparing main for 36" linestop sleeve.



36" linestop sleeve.



Installing linestop sleeve.



Sleeve ready for concrete foundation.